Recorded: 9/9/2019 at 10:50:27.0 AM
County Recording Fee: $0.00
Iowa E-Filing Fee: $0.00
Combined Fee: $0.00
Revenue Tax:
Delaware County, Iowa
Daneen Schindler RECORDER
BK: 2019 PG: 2451

REAL ESTATE TRANSFER - GROUNDWATER HAZARD STATEMENT

TO BE COMPLETED BY TRANSFEROR

TRANSFEROR:

Name See 1 in Addendum

Address _____

Number and Street or RR | City, Town or P.O. | State | Zip

TRANSFEREE:

Name Diane E. Bauers and Allen L. Bauers

Address 20641 261st St., Delhi, IA 52223

Number and Street or RR | City, Town or P.O. | State | Zip

Address of Property Transferred:
20641 261st St., Delhi, IA 52223

Number and Street or RR | City, Town or P.O. | State | Zip

Legal Description of Property: (Attach if necessary) Lots 89 and 92 of "Clair-View Acres at Delhi, Iowa" in Sections 23 and 26, Milo Township, Delaware County, Iowa, according to plat recorded in Book 2 Plats, Page 200; same being a part of the Northwest Quarter of the Northeast Quarter of Section 26, Township 88 North, Range 5 West of the 5th P.M.

1. **Wells (check one)**
   - ___ There are no known wells situated on this property.
   - X There is a well or wells situated on this property. The type(s), location(s) and legal status are stated below or set forth on an attached separate sheet, as necessary.
2. **Solid Waste Disposal (check one)**
   - X There is no known solid waste disposal site on this property.
   - ___ There is a solid waste disposal site on this property and information related thereto is provided in Attachment #1, attached to this document.
3. **Hazardous Wastes (check one)**
   - X There is no known hazardous waste on this property.
   - ___ There is hazardous waste on this property and information related thereto is provided in Attachment #1, attached to this document.
4. **Underground Storage Tanks (check one)**
   - X There are no known underground storage tanks on this property. (Note exclusions such as small farm and residential motor fuel tanks, most heating oil tanks, cisterns and septic tanks, in instructions.)
   - ___ There is an underground storage tank on this property. The type(s), size(s) and any known substance(s) contained are listed below or on an attached separate sheet, as necessary.

5. **Private Burial Site (check one)**
   - X There are no known private burial sites on this property.
   - ___ There is a private burial site on this property. The location(s) of the site(s) and known identifying information of the decedent(s) is stated below or on an attached separate sheet, as necessary.

6. **Private Sewage Disposal System (check one)**
   - ___ All buildings on this property are served by a public or semi-public sewage disposal system.
   - ___ This transaction does not involve the transfer of any building which has or is required by law to have a sewage disposal system.
   - X There is a building served by private sewage disposal system on this property or a building without any lawful sewage disposal system. A certified inspector's report is attached which documents the condition of the private sewage disposal system and whether any modifications are required to conform to standards adopted by the Department of Natural Resources. A certified inspection report must be accompanied by this form when recording.
   - ___ There is a building served by private sewage disposal system on this property. Weather or other temporary physical conditions prevent the certified inspection of the private sewage disposal system from being conducted. The buyer has executed a binding acknowledgment with the county board of health to conduct a certified inspection of the private sewage disposal system at the earliest practicable time and to be responsible for any required modifications to the private sewage disposal system as identified by the certified inspection. A copy of the binding acknowledgment is attached to this form.
   - ___ There is a building served by private sewage disposal system on this property. The buyer has executed a binding acknowledgment with the county board of health to install a new private sewage disposal system on this property within an agreed upon time period. A copy of the binding acknowledgment is provided with this form.
   - ___ There is a building served by private sewage disposal system on this property. The building to which the sewage disposal system is connected will be demolished without being occupied. The buyer has executed a binding acknowledgment with the county board of health to demolish the building within an agreed upon time period. A copy of the binding acknowledgment is provided with this form. [Exemption #9]
   - ___ This property is exempt from the private sewage disposal inspection requirements pursuant to the following exemption [Note: for exemption #9 use prior check box]: _____.
   - ___ The private sewage disposal system has been installed within the past two years pursuant to permit number _____.

Information required by statements checked above should be provided here or on separate sheets attached hereto:
WELL LOCATION RIGHT NEXT TO DRIVE WAY IN FLOWER BED

I HEREBY DECLARE THAT I HAVE REVIEWED THE INSTRUCTIONS FOR THIS FORM AND THAT THE INFORMATION STATED ABOVE IS TRUE AND CORRECT.

Signature: Gerald Ewal (Transferor or Agent) Telephone No.: 563-5590444

FILE WITH RECORDER **DNR form 542-0960 (July 18, 2012)**

Addendum

1. Sheree Cupps and Joseph Cupps, Jerald Walen, Sherryl Walen, Barry Walen, Patricia Walen, Karen Newman, Shawn Newman, Terrance A. Walen and Kristin Meany-Walen

Addendum

1. Sheree Cupps and Joseph Cupps, Jerald Walen, Sherryl Walen, Barry Walen, Patricia Walen, Karen Newman, Shawn Newman, Terrance A. Walen and Kristin Meany-Walen
2. Lots 89 and 92 of "Clair-View Acres at Delhi, Iowa" in Sections 23 and 26, Milo Township, Delaware County, Iowa, according to plat recorded in Book 2 Plats, Page 200; same being a part of the Northwest Quarter of the Northeast Quarter of Section 26, Township 88 North, Range 5 West of the 5th P.M.

Time of Transfer Inspection Report (DNR Form 542-0191)

Property information

Current Owner: Jerry&Terry Walen

Buyer: _____ Realtor: Susie Meyer

Mailing Address: 1749 Richie Drive Dubuque Iowa

Site Address/County: 20641 261st Delhi, Iowa

No. of Bedrooms: 4 Last Occupied? part time Disposal? Y / N Softener? Y / N H_2O Supply? well

Records Available: yes Permit/Installation Date: 9/29/2003 permit#1188 Installer: Harback

Septic System Information

Septic Tank(s): Size: 1250 Material: concrete Condition: good

Tank Pumped?: yes Date: 6/4/2019 Licensed Pumper: st-49

Septic/Trash/Processing Tank: Size: na Material: na Condition: na

Tank pumped?: na Date: na Licensed Pumper: na

Aerobic treatment unit (ATU) MFGR: na Size: na

Tank Pumped?: na Date: na Licensed Pumper: na

Maintenance Contract?: na Expiration Date: na Service Provider: na

Condition: na

Pump Ttanks/Vaults: Type: na Size: na Condition: na

Distribution System: Distribution Box: yes Outlets Used: 3 Condition: fair

Header Pipe(s): no Number of Lines: 3@40'

Pressure Dosed?: no

Secondary Treatment

Length of Absorption Fields: Bed 10x40 Determined by: perma & map

Condition of Fields: good Determined by: hydraulic load test

Type of Trench Material: rock&pipe

Size of Sand Filter: na Determined by: na

Vent Pipes Above Grade?: na Discharge Pipe Located?: na

Effluent Sample Taken?: na Results: na

Media Filters: Type: na

Maintenance Contract?: na Expiration Date: na Service Provider: na

Condition: na

NPDES General Permit No. 4: Required?: na Permitted?: na NOI submitted: na

Time of Transfer Inspection Worksheet

Other Components

Alarms no Working? na Disinfection no Working? na

Control Box no Timers no Inspection Ports no

Other Components none

Overall condition of the private sewage disposal system

Acceptable? _____ Unacceptable? _____

Explain (attach additional pages as needed): _____

Comments: _____

Site status at conclusion of Time of Transfer inspection:

Verify that controls are set on the appropriate mode.
Power is on to all components.
Revisit all components to verify lids are secure.
Gather all tools for removal from the site.
Verify that no sewage is on the ground surface.

Using this worksheet, write a narrative report of the inspection results.

Submit a copy of this report, including your narrative, to the city/county environmental health office, the DNR and the county Recorder in the county where the inspection was conducted.

This report indicates the condition of the private sewage disposal system at the time of the inspection. It does not guarantee that it will continue to function satisfactorily.

Signature of Certified Inspector: Luke Ogden Date: 6/10/2019

Name (print): Luke Ogden Certificate #: 6715

Address: 207 Quaker mill road Manchester Iowa

Phone # 563-927-6503

OASIS PUMP SERVICE
1332 N. Franklin, Manchester, Iowa 52057
563-927-6503 888-666-6503
www.oasiswell.com

Septic Inspection
Terry & Jerry Walen
20641 261st St.
Delhi, IA 52223

On May 31, 2019 a septic inspection was performed at the above address.

Description:

Home is a manufactured home with 4 bedrooms, 2 baths and is approximately 1600 sq. feet. Home was built in 2003 – part time cabin.

Septic Description/Condition:

Septic system consists of 1 – 1,250 gallon 2 compartment concrete septic tank, 1 – 7 hole distribution box. Leach field is rock and pipe, bed is 10 x 40. Septic system was installed new on May 28, 2003. Septic tank was pump on June 4, 2019 and septic inspection was completed on 5/31/19. A hydraulic load test was performed at 6 GPM for 60 minutes. Leach field accepted water fine.

Company Disclaimer

Based on what we were able to observe and our experience with on-site wastewater technology, we submit this sanitary sewage disposal system inspection report based on the present condition of the on-site sewage disposal system. Oasis Pump Service has not been retained to warrant, guarantee, or certify the proper functioning of the system for any period of time in the future. Because of numerous factors (usage, soil characteristics, previous failures, etc.) which effect the proper operation of a septic system as well as the inability of our Company to supervise or monitor the use or maintenance of the system, this report shall not be constructed as a warranty by our Company that the system will function properly for any particular buyer. Oasis Pump Service **DISCLAIMS ANY WARRANTY**, either expressed or implied, arising from the inspection of the septic system or this report. We are also not ascertaining the impact the system is having on the ground water.

I have studied the information contained herein and that my assessment is honest, thorough, and, to the best of my ability correct.

Certified by Luke Ogden #6715


Luke Ogden **Date** 6/10/19

Owner: **Terry & Jerry Walen 20641 261st St. Delhi, IA 52223**

OASIS
PUMP SERVICE
1332 N. Franklin, Manchester, Iowa 52057
563-927-6503 888-666-6503
www.oasiswell.com

OWNER: Jerry Walen
DATE: 6/10/2019
SITE ADDRESS: 20641 261st street
TOWN/COUNTY: Delhi Iowa
GPS: Long: Lat:
TANK SIZE: 1250 Plastic OR (Concrete) D-BOX: (2) or 3 OUTLETS USED: 3
SECONDARY TREATMENT: Small Bed Rock & Pipe
Hole in tank 6" to seal 10-10

A-1 = 8'
A-2 = 8' 6"
A-3 = 11' 9"
B-1 = 62'
B-2 = 58' 4"
B-3 = 54' 2"



261 St

1250-23-07-098.00

1144

DELAWARE COUNTY
BOARD OF SUPERVISORS

(Print or Type)

Permit No. [redacted]

APPLICATION FOR PERMIT TO INSTALL PRIVATE SEWAGE DISPOSAL SYSTEM

ADDRESS: 20641 261st St. Section 26 Township Del. Co.

LOCATION: NE¼ sec 26 - T-80N R-5W

Owner: Bill Phelps Tenant: _____ Plumber: Harbaugh

Lot Size: 60x200 Type Commercial: _____ Residential: (No. Bedrooms) 3

Fixtures: Stools 3 Lavatories ___ Bath Tubs 2 Showers 2 Sinks 3 Automatic Laundry 1 Sump Pump ___

Septic Tank made by _____ Garbage Grinder _____ Construction Material _____ Gallons Cap. 1250

Percolation Test: 1. _____ 2. _____ 3. _____ 4. _____ Made by: _____

Absorption Field: Total length of laterals _____ No. of lateral lines _____

This system is new ✓ Existing ___ 10x60 - Bed

I certify that the above information is correct and that all proposed work will be completed in accordance with the Delaware County Regulations.

Date Approved 5-28-03

By _____
INSPECTOR

Bill Phelps
APPLICANT'S SIGNATURE

SEAL

DELAWARE COUNTY
BOARD OF SUPERVISORS (Print or Type) Permit No. 11505

APPLICATION FOR PERMIT TO INSTALL PRIVATE SEWAGE DISPOSAL SYSTEM

ADDRESS: 20641 261st St. Section 26 Township M/L

LOCATION: NE¼ sec 26 - T-98N R-5W

Owner: Bill Phelps Tenant: _____ Plumber: Hackney

Lot Size: 60x200 Type Commercial: _____ Residential: (No. Bedrooms) 3

Fixtures: Stools 3 Lavatories ___ Bath Tubs 2 Showers 2 Sinks 2 Automatic Laundry / Sump Pump ___

Septic Tank made by _____ Garbage Grinder _____ Construction Material _____ Gallons Cap. _____

Percolation Test: 1. _____ 2. _____ 3. _____ 4. _____ Made by: _____


Absorption Field: Total length of laterals _____ No. of lateral lines _____

This system is new ✓ Existing _____. 10x40 - Bed

I certify that the above information is correct and that all proposed work will be completed in accordance with the Delaware County Regulations.

Date Approved 5-28-03 Bill Phelps
APPLICANT'S SIGNATURE

By Dennis Lee
INSPECTOR SEAL



261st St