Recorded: 1/8/2021 at 8:19:54.0 AM
County Recording Fee: $0.00
Iowa E-Filing Fee: $0.00
Combined Fee: $0.00
Revenue Tax:
Delaware County, Iowa
Daneen Schindler RECORDER
BK: 2021 PG: 106

REAL ESTATE TRANSFER - GROUNDWATER HAZARD STATEMENT

TO BE COMPLETED BY TRANSFEROR

TRANSFEROR:

Name Zachary A. Muller

Address 1500 North Franklin Street, Manchester, IA 52057

Number and Street or RR | City, Town or P.O. | State | Zip

TRANSFEREE:

Name Matthew L. and Danelle M. Hudspeth

Address 206 Kohlst, Martelle, IA 52305

Number and Street or RR | City, Town or P.O. | State | Zip

Address of Property Transferred:
25846 217th Avenue, Delhi, IA 52223

Number and Street or RR | City, Town or P.O. | State | Zip

Legal Description of Property: (Attach if necessary) Lots Nineteen (19) and Twenty (20) of Camp-O-Delhi, a Subdivision of the Southwest Quarter (SW 1/4) of the Southeast Quarter (SE 1/4) of Section Twenty Four (24), Township Eighty Eight (88) North, Range Five (5), West of the Fifth P.M., in Delaware County, Iowa, according to plat recorded in Book 5 Plats, Page 78

1. **Wells (check one)**
   - X There are no known wells situated on this property.
   - ___ There is a well or wells situated on this property. The type(s), location(s) and legal status are stated below or set forth on an attached separate sheet, as necessary.
2. **Solid Waste Disposal (check one)**
   - X There is no known solid waste disposal site on this property.
   - ___ There is a solid waste disposal site on this property and information related thereto is provided in Attachment #1, attached to this document.
3. **Hazardous Wastes (check one)**
   - X There is no known hazardous waste on this property.
   - ___ There is hazardous waste on this property and information related thereto is provided in Attachment #1, attached to this document.
4. **Underground Storage Tanks (check one)**
   - X There are no known underground storage tanks on this property. (Note exclusions such as small farm and residential motor fuel tanks, most heating oil tanks, cisterns and septic tanks, in Instructions.)
   - ___ There is an underground storage tank on this property. The type(s), size(s) and any known substance(s) contained are listed below or on an attached separate sheet, as necessary.

5. **Private Burial Site (check one)**
   - X There are no known private burial sites on this property.
   - ___ There is a private burial site on this property. The location(s) of the site(s) and known identifying information of the decedent(s) is stated below or on an attached separate sheet, as necessary.
6. **Private Sewage Disposal System (check one)**
   - ___ All buildings on this property are served by a public or semi-public sewage disposal system.
   - ___ This transaction does not involve the transfer of any building which has or is required by law to have a sewage disposal system.
   - X There is a building served by private sewage disposal system on this property or a building without any lawful sewage disposal system. A certified inspector's report is attached which documents the condition of the private sewage disposal system and whether any modifications are required to conform to standards adopted by the Department of Natural Resources. A certified inspection report must be accompanied by this form when recording.
   - ___ There is a building served by private sewage disposal system on this property. Weather or other temporary physical conditions prevent the certified inspection of the private sewage disposal system from being conducted. The buyer has executed a binding acknowledgment with the county board of health to conduct a certified inspection of the private sewage disposal system at the earliest practicable time and to be responsible for any required modifications to the private sewage disposal system as identified by the certified inspection. A copy of the binding acknowledgment is attached to this form.
   - ___ There is a building served by private sewage disposal system on this property. The buyer has executed a binding acknowledgment with the county board of health to install a new private sewage disposal system on this property within an agreed upon time period. A copy of the binding acknowledgment is provided with this form.
   - ___ There is a building served by private sewage disposal system on this property. The building to which the sewage disposal system is connected will be demolished without being occupied. The buyer has executed a binding acknowledgment with the county board of health to demolish the building within an agreed upon time period. A copy of the binding acknowledgment is provided with this form. [Exemption #9]
   - ___ This property is exempt from the private sewage disposal inspection requirements pursuant to the following exemption [Note: for exemption #9 use prior check box]: _____.
   - ___ The private sewage disposal system has been installed within the past two years pursuant to permit number _____.

Information required by statements checked above should be provided here or on separate sheets attached hereto:

_____

_____

_____

_____

I HEREBY DECLARE THAT I HAVE REVIEWED THE INSTRUCTIONS FOR THIS FORM AND THAT THE INFORMATION STATED ABOVE IS TRUE AND CORRECT.

Signature: Susan K Meyer (Transferor or Agent) Telephone No.: (563) 608-6320

542-0191

Time of Transfer Inspection Report

1250 24-202000

Property Information

Current Owner: Straightline Construction

Buyer: _____ Realtor: _____

Site Address/County: 25840 217Th Ave Delhi, Iowa

Legal Description 25840 217th Ave Delhi, Iowa

No. of bedrooms: 1 Last occupied: Present Records available: _____

Permit/ installation date: _____ Separation distances (ok/no?): Okay

Septic System information

Septic tank(s): Size: 1750 Holding Tank Material: Concrete Condition: Good

Tank pumped? XY N Date: 6/13/19 Licensed pumper: Triple J

Septic/Trash/Processing tank: Size: _____ Material: _____ Condition: _____

Tank pumped? ☐ Y ☐ N Date: _____ Licensed pumper: _____

Aerobic treatment unit (ATU) mfgr _____ Size _____

Tank pumped? ☐ Y ☐ N Date: _____ Licensed pumper: _____

Maintenance contract? ☐ Y ☐ N Expiration date: _____ Service provider: _____

Condition: _____

Pump tanks/vaults: Type: _____ Size: _____ Condition: _____

Distribution system: Distribution box _____ Outlets used _____ Condition: _____

Header pipe(s): _____ No. of lines: _____ Pressure dosed? _____

Secondary Treatment:

Length of absorption fields: _____ Determined by: _____

Condition of fields: _____ Determined by: _____

Type of trench material: _____

Size of sand filter: _____ Determined by: _____

Vent pipes above grade? ☐ Y ☐ N Discharge pipe located? ☐ Y ☐ N

Effluent sample taken No Discharge Results: N/A

Media Filters: Type: _____

Maintenance contract? ☐ Y ☐ N Expiration date: _____ Service provider: _____

Condition: _____

NPDES General Permit No. 4: Required? ☐ Y ☐ N Permitted? ☐ Y ☐ N NOI provided: _____

Time of Transfer Inspection Report

Other components:

Alarms: ☐ Y ☐ N Working: ☐ Y ☐ N Disinfection: ☐ Y ☐ N Working: ☐ Y ☐ N

Control Box: _____ Timers: _____ Inspection Ports: _____

Other components: _____

Overall condition of the private sewage disposal system:

Report system status: _____

Explain (attach additional pages as needed): _____

Comments: System working properly at time of inspection. Holding tank only.

Site status at conclusion of Time of Transfer inspection:

- Verify that controls are set on the appropriate mode.
- Power is on to all components.
- Revisit all components to verify lids are secure.
- Gather all tools for removal from the site.
- Verify that no sewage is on the ground surface.

Using this worksheet, write a narrative report of the inspection results and attach a site sketch.

This report indicates the condition of the private sewage disposal system at the time of the inspection. It does not guarantee that it will continue to function satisfactorily.

Signature of Certified Inspector: Jason Brimeyer Date: 6-18-19

Name (print): Jason Brimeyer Certificate #: 9446

Address: 23775 Pilot Grove Rd Epworth, Iowa 52045

Phone #: 563-590-2471

Provide a copy of this report, the narrative report and sketch to the seller/agent, buyer/agent or the person ordering the inspection, the county sanitarian/environmental health office and to:

Iowa DNR Private Sewage Disposal Program 502 E 9th St Des Moines IA 50319


217th AVE
House
Driveway
25840 217th Ave