



Document 2019 GW2405

Book 2019 Page 2405 Type 43 001 Pages 6
Date 8/05/2019 Time 12:56:10PM
Rec Amt \$.00

INDX
ANNO
SCAN
CHEK

LISA SMITH, COUNTY RECORDER
MADISON COUNTY IOWA

**REAL ESTATE TRANSFER - GROUNDWATER HAZARD STATEMENT
TO BE COMPLETED BY TRANSFEROR**

TRANSFEROR:

Name Troy Kerr and Amy Christensen
Address 11541 Northwest 107th Ct, Granger, IA 50109
Number and Street or RR City, Town or P.O. State Zip

TRANSFeree:

Name Amber L. Sexton and Chad J. Sexton
Address 2206 Holliwell Valley Court, Winterset, IA 50273
Number and Street or RR City, Town or P.O. State Zip

Address of Property Transferred:
2206 Holliwell Valley Court, Winterset, IA 50273
Number and Street or RR City, Town or P.O. State Zip

Legal Description of Property: (Attach if necessary) Lot Two (2) of Holliwell Valley Subdivision, located in the Northeast Quarter (1/4) of Section Five (5), in Township Seventy-five (75) North, Range Twenty-seven (27) West of the 5th P.M., Madison County, Iowa.

1. Wells (check one)

- There are no known wells situated on this property.
- There is a well or wells situated on this property. The type(s), location(s) and legal status are stated below or set forth on an attached separate sheet, as necessary.

2. Solid Waste Disposal (check one)

- There is no known solid waste disposal site on this property.
- There is a solid waste disposal site on this property and information related thereto is provided in Attachment #1, attached to this document.

3. Hazardous Wastes (check one)

- There is no known hazardous waste on this property.
- There is hazardous waste on this property and information related thereto is provided in Attachment #1, attached to this document.

4. Underground Storage Tanks (check one)

- There are no known underground storage tanks on this property. (Note exclusions such as small farm and residential motor fuel tanks, most heating oil tanks, cisterns and septic tanks, in instructions.)
- There is an underground storage tank on this property. The type(s), size(s) and any known substance(s) contained are listed below or on an attached separate sheet, as necessary.

5. Private Burial Site (check one)

- There are no known private burial sites on this property.
- There is a private burial site on this property. The location(s) of the site(s) and known identifying information of the decedent(s) is stated below or on an attached separate sheet, as necessary.

6. Private Sewage Disposal System (check one)

- All buildings on this property are served by a public or semi-public sewage disposal system.
- This transaction does not involve the transfer of any building which has or is required by law to have a sewage disposal system.
- There is a building served by private sewage disposal system on this property or a building without any lawful sewage disposal system. A certified inspector's report is attached which documents the condition of the private sewage disposal system and whether any modifications are required to conform to standards adopted by the Department of Natural Resources. A certified inspection report must be accompanied by this form when recording.
- There is a building served by private sewage disposal system on this property. Weather or other temporary physical conditions prevent the certified inspection of the private sewage disposal system from being conducted. The buyer has executed a binding acknowledgment with the county board of health to conduct a certified inspection of the private sewage disposal system at the earliest practicable time and to be responsible for any required modifications to the private sewage disposal system as identified by the certified inspection. A copy of the binding acknowledgment is attached to this form.
- There is a building served by private sewage disposal system on this property. The buyer has executed a binding acknowledgment with the county board of health to install a new private sewage disposal system on this property within an agreed upon time period. A copy of the binding acknowledgment is provided with this form.
- There is a building served by private sewage disposal system on this property. The building to which the sewage disposal system is connected will be demolished without being occupied. The buyer has executed a binding acknowledgment with the county board of health to demolish the building within an agreed upon time period. A copy of the binding acknowledgment is provided with this form. [Exemption #9]
- This property is exempt from the private sewage disposal inspection requirements pursuant to the following exemption [Note: for exemption #9 use prior check box]: _____.
- The private sewage disposal system has been installed within the past two years pursuant to permit number _____.

Information required by statements checked above should be provided here or on separate sheets attached hereto:

I HEREBY DECLARE THAT I HAVE REVIEWED THE INSTRUCTIONS FOR THIS FORM AND THAT THE INFORMATION STATED ABOVE IS TRUE AND CORRECT.

Signature: 
(Transferor or Agent)

Telephone No.: (425) 218-6549



Time of Transfer Inspection Report (DNR Form 542-0191)

Property information

Current owner Troy Kerr
Buyer CHAD & AMBER SEYTON Realtor SARAH COWMAN
Mailing address 2206 Halliwell Valley CT Winsterset, IA 50273
Site Address/County SAME AS ABOVE / MADISON CO
Legal Description AS ABSTRACT
No. of bedrooms 4 Last occupied? Present Records available YES
Permit/installation date 064-04 Separation distances ok/no? OK
10-1-04

Septic system information

Septic tank(s): size 1500 gal material Concrete condition OK
Tank pumped? yes date 7-1-19 licensed pumper Country Side Septic
Septic/trash/processing tank: size material condition
Tank pumped? date licensed pumper
Aerobic treatment unit (ATU) mfg size
Tank pumped? date licensed pumper
Maintenance contract? expiration date service provider
Condition
Pump tanks/vaults: type size condition
Distribution system: distribution box YES outlets used 4 condition OK (see Notes)
Header pipe(s) # of lines Pressure dosed?
Secondary treatment:
length of absorption fields 4 100' determined by County Records
condition of fields OK - DRY determined by PROBING & Hydraulic
type of trench material CHAMBER TEST
Size of sand filter determined by
Vent pipes above grade? discharge pipe located?
Effluent sample taken? Results
Media filters: type
Maintenance contract? expiration date service provider
Condition
NPDES General Permit No. 4: required? permitted? NOI provided



Time of Transfer Inspection Report

Other components:

Alarms NO Working? _____ disinfection NO working? _____

Control box _____ Timers _____ inspection ports _____

Other components Sump pump For Ground WATER AND ejector pump For BATHROOM IN BASEMENT.

Overall condition of the private sewage disposal system

Report system status See ATTACHED PAGES.

Explain (attach additional pages as needed): _____

Comments: ONE speed Leveler WAS LAYING IN BOTTOM OF DISTRIBUTION BOX, I INSTALLED IT AND Leveled ALL LATERAL LINES LEAVING BOX.

Site status at conclusion of Time of Transfer inspection:

- Verify that controls are set on the appropriate mode.
- Power is on to all components.
- Revisit all components to verify lids are secure.
- Gather all tools for removal from the site.
- Verify that no sewage is on the ground surface.

Using this worksheet, write a narrative report of the inspection results and attach a site sketch.

This report indicates the condition of the private sewage disposal system at the time of the inspection. It does not guarantee that it will continue to function satisfactorily.

Signature of Certified inspector: [Signature] Date: 7-1-19
 Name (print): BRIAN KIRWAN Certificate #: 8805
 Address: P.O. Box 204 NORWALK, IA 50211
 Phone #: 202-4895

Provide a copy of this report, the narrative report and sketch to the seller/agent, buyer/agent or the person ordering the inspection, the county sanitarian/environmental health office, and to;

Iowa DNR
 Private Sewage Disposal Program
 502 E. 9th St.
 Des Moines, IA 50319

Time of Transfer Report System Status

Address: 2206 Holliswell Valley Ct Date: 7-1-19

Comments: Winterset, IA 50273 Technician: Brian Rinard

All WASTEWATER FROM HOUSE APPEARS TO
DRAIN INTO SEPTIC SYSTEM.

1500 GALLON CONCRETE (2) COMPARTMENT SEPTIC
TANK WITH RISERS AND EFFLUENT FILTER WAS
IN WORKING CONDITION.

PLASTIC DISTRIBUTION BOX WITH INLET Baffle
AND Speed Levelers USED WAS ALSO IN WORKING
CONDITION. All (4) 100' Chamber Laterals TOOK
WATER AND PROBED DRY AT TIME OF INSPECTION

THIS IS NOT A GUARANTEE

THIS CERTIFIES THAT THE SEPTIC SYSTEM WAS
IN WORKING CONDITION AT TIME OF THE INSPECTION

DIAGRAM OF SYSTEM


See
County
Records

From: Tina Burk (tburk@madison.com)
Subject: 2206 Holliswell

Date: Jun 27, 2019 at 8:01:13 AM

To: Brian Rinard (countryrides@ptd.net)

Permit # 524-04 2206 Holliswell 10/1/04
2206 Holliswell Valley, CT



No Drains