

BK: 2023 PG: 1777
Recorded: 8/1/2023 at 3:50:51.0 PM
Pages 5
County Recording Fee: \$0.00
Iowa E-Filing Fee: \$0.00
Combined Fee: \$0.00
Revenue Tax:
BRANDY L. MACUMBER, RECORDER
Madison County, Iowa

**REAL ESTATE TRANSFER - GROUNDWATER HAZARD STATEMENT
TO BE COMPLETED BY TRANSFEROR**

If the transaction is exempt from filing a declaration of value pursuant to Iowa Code 428A.1(2), **STOP HERE**. Pursuant to Iowa Code section 558.69(1), when no declaration of value is submitted during a transaction, you are not required to submit a groundwater hazard statement or include the statutory language in Iowa Code section 558.69(8A). Please consult your realtor or legal counsel for further advice, including on whether a declaration of value is required. The Department provides this information for statutory reference only.

Instructions for this document can be found at:

<https://www.iowadnr.gov/Portals/idnr/uploads/forms/5420960%20Instructions.pdf>

Attachment 1, if required, can be found at: <https://www.iowadnr.gov/Portals/idnr/uploads/forms/5420960a.pdf>

TRANSFEROR:

Name: Nelson Ivyl Ransom and Katherine Sue Ransom
Address: 700 W. North St., Truro, IA 50257

TRANSFeree:

Name: Zachery K. Gray and Rachel L. Gray
Address: 3214 Valleyview Ave., Truro, IA 50257

Address of Property Transferred:

3214 Valleyview Ave., Truro, Iowa 50257

Legal Description of Property: (Attach if necessary)

Parcel "D" located in the Northwest Quarter (¼) of the Northwest Quarter (¼) of Section Twenty-seven (27), Township Seventy-four (74) North, Range Twenty-six (26) West of the 5th P.M., Madison County, Iowa, containing 5.13 acres, as shown in Plat of Survey filed in Book 2022, Page 3009 on October 17, 2022, in the Office of the Recorder of Madison County, Iowa.

1. Wells (check one)

- No Condition - There are no known wells situated on this property.
 Condition Present - There is a well or wells situated on this property. The type(s), location(s) and legal status are stated below or set forth on an attached separate sheet, as necessary.

2. Solid Waste Disposal (check one)

- No Condition - There is no known solid waste disposal site on this property.
 Condition Present - There is a solid waste disposal site on this property and information related thereto is provided in Attachment #1, attached to this document.

3. Hazardous Wastes (check one)

3. Hazardous Wastes (check one)

- No Condition - There is no known hazardous waste on this property.
- Condition Present - There is hazardous waste on this property and information related thereto is provided in Attachment #1, attached to this document.

4. Underground Storage Tanks (check one)

- No Condition - There are no known underground storage tanks on this property. (Note exclusions such as small farm and residential motor fuel tanks, most heating oil tanks, cisterns and septic tanks, in instructions.)
- Condition Present - There is an underground storage tank on this property. The type(s), size(s) and any known substance(s) contained are listed below or on an attached separate sheet, as necessary.

5. Private Burial Site (check one)

- No Condition - There are no known private burial sites on this property.
- Condition Present - There is a private burial site on this property. The location(s) of the site(s) and known identifying information of the decedent(s) is stated below or on an attached separate sheet, as necessary.

6. Private Sewage Disposal System (check one)

- No Condition - All buildings on this property are served by a public or semi-public sewage disposal system.
- No Condition - This transaction does not involve the transfer of any building which has or is required by law to have a sewage disposal system.
- Condition Present - There is a building served by private sewage disposal system on this property or a building without any lawful sewage disposal system. A certified inspector's report is attached which documents the condition of the private sewage disposal system and whether any modifications are required to conform to standards adopted by the Department of Natural Resources. A certified inspection report must be accompanied by this form when recording.
- Condition Present - There is a building served by private sewage disposal system on this property. Weather or other temporary physical conditions prevent the certified inspection of the private sewage disposal system from being conducted. The buyer has executed a binding acknowledgment with the county board of health to conduct a certified inspection of the private sewage disposal system at the earliest practicable time and to be responsible for any required modifications to the private sewage disposal system as identified by the certified inspection. A copy of the binding acknowledgment is attached to this form.
- Condition Present - There is a building served by private sewage disposal system on this property. The system is failing to ensure effective wastewater treatment or is otherwise improperly functioning, and the buyer has executed a binding acknowledgment with the county board of health to install a new private sewage disposal system on this property within an agreed upon time period. A copy of the binding acknowledgment is provided with this form.
- Condition Present - There is a building served by private sewage disposal system on this property. The building to which the sewage disposal system is connected will be demolished without being occupied. The buyer has executed a binding acknowledgment with the county board of health to demolish the building within an agreed upon time period. A copy of the binding acknowledgment is provided with this form. [Exemption #7]
- Condition Present - There is a building served by private sewage disposal system on this property. This property is exempt from the private sewage disposal inspection requirements pursuant to the following Exemption [Note: for exemption #7 use prior check box]:

- Condition Present - There is a building served by private sewage disposal system on this property. The private sewage disposal system has been installed within the past two years pursuant to permit number:

Review the following two directions carefully:

- A. If you selected a box stating "No Condition" for every numbered section above, **STOP HERE**. Do not submit this form. Instead, pursuant to Iowa Code section 558.69(8A), you must include the following language on the first page of

the recorded deed, instrument, or other writing:

“There is no known private burial site, well, solid waste disposal site, underground storage tank, hazardous waste, or private sewage disposal system on the property as described in Iowa Code section 558.69, and therefore the transaction is exempt from the requirement to submit a groundwater hazard statement.”

Please consult your realtor or legal counsel for further advice on this exemption. By law, the owner of the property is responsible for the accuracy of this statement, and the Department provides this information for statutory reference only.

- B. If you checked any box stating “Condition Present” for any of the numbered sections above, continue below. You must complete this form, including providing all required information, and you must submit this form to the county recorder’s office with declaration of value.

Information required by statements checked above should be provided here or on separate sheets attached hereto:

I HEREBY DECLARE THAT I HAVE REVIEWED THE INSTRUCTIONS FOR THIS FORM AND THAT THE INFORMATION STATED ABOVE IS TRUE AND CORRECT.

Signature: Nelson Inghram Parsons Katherine Lee Parsons Telephone No.: (515) 669-6559
(Transferor)



IOWA DEPARTMENT of NATURAL RESOURCES
 TIME OF TRANSFER INSPECTION WAIVER
 BINDING AGREEMENT for FUTURE INSTALLATION
 542-0064

This agreement is entered into this 3 day of July, 2023 by and
 between the Madison County Board of Health and Zack Gray

It is understood that Iowa Code 455B.172(11) requires an inspection of the private sewage disposal system on all properties not specifically exempted in Iowa at the time of transfer.

The property located at 3214 Valleyview Ave, Iowa is subject to the inspection and the buyer Zack Gray understands there is not an adequate private sewage disposal system serving this property.

It is hereby agreed that the time of transfer inspection will not be required and the buyer agrees that a code compliant private sewage disposal system or connection to a public sewer shall be installed to serve the property and shall be completed no later than 3 day of September, 2023

3 day of July, 2023

[Signature]
 BUYER

[Signature]
 COUNTY BOARD OF HEALTH
 AUTHORIZED REPRESENTATIVE

It was acknowledged before me on July 3, 2023

by [Signature]
[Signature]
 Notary Public



MADISON COUNTY ENVIRONMENTAL HEALTH SEPTIC INSPECTION REPORT - LATERAL SYSTEM

General Information

Owner: Ransom, Nelson Ivyl & Katherin (DED) Installer: Finley
Address: 3214 VALLEYVIEW AVE
Inspection Date/s: 07/21/2023 Inspected by: X

System Details: Rock and Pipe SB2 Chambers EPS Aggregate

Sewer Pipe from Building to Primary Treatment

Sewer Pipe was installed in accordance with Chapter 69.7(1)-(3) & 69.9(1)g: Yes or No
If no, explain Yes

Septic Tank

Septic Tank Size 1250 1500 1750 2000 Other Material: Concrete
 septic tank only Plastic
 +500 gallon pump /siphon combination tank
 + Separate gallon pump/siphon tank Source: Indianola
Septic tank was installed in accordance with Chapter 69.8(2)- 69.8(3): Yes or No
If no, explain Yes

Piping from Tank to Distribution Box and Distribution Box

Piping after tank & d- box were installed according to Chapter 69.9(8)b-g & 69.8(11): Yes No or N/A
If no, explain NA

Pump System

Pump system was installed according to Chapter 69.9(9): Yes No or N/A
If no, explain NA

Construction Specifications

Lateral Feet required 300 Lateral Fee installed 300
Number of Lateral lines 3 Length of Lines (100' max) 100
Width of trenches (18"-36") 36 Depth of Trenches(36" max) 32

Laterals were installed in accordance with Chapter 69.9(1)-(8) & Tables III A,B,C,D : Yes or No
If no, explain Yes

Minimum Distances for Closed and Open Portions of Treatment System

Both open and closed portion the the septic system have been installed in accordance with the minimum distances listed in Table 1 of Chapter 69.3(2): Yes No
If no, explain Yes

Final Review: Approved or Disapproved