

BK: 2024 PG: 587
Recorded: 3/19/2024 at 1:10:00.0 PM
Pages 8
County Recording Fee: \$0.00
Iowa E-Filing Fee: \$0.00
Combined Fee: \$0.00
Revenue Tax: \$0.00
BRANDY L. MACUMBER, RECORDER
Madison County, Iowa

REAL ESTATE TRANSFER - GROUNDWATER HAZARD STATEMENT
TO BE COMPLETED IN FULL BY TRANSFEROR

If the transaction is exempt from filing a declaration of value pursuant to Iowa Code 428A.1(2), **STOP HERE**. Pursuant to Iowa Code section 558.69(1), when no declaration of value is submitted during a transaction, you are not required to submit a groundwater hazard statement or include the statutory language in Iowa Code section 558.69(8A). Please consult your realtor or legal counsel for further advice, including on whether a declaration of value is required. The Department provides this information for statutory reference only.

Instructions for this document can be found at:

<https://www.iowadnr.gov/Portals/idnr/uploads/forms/5420960%20Instructions.pdf>

Attachment 1, if required, can be found at: <https://www.iowadnr.gov/Portals/idnr/uploads/forms/5420960a.pdf>

TRANSFEROR:

Name Nicole E. Williams

Address 780 Hull Avenue, Lewisburg, TN 37091

Number and Street or RR

City, Town or PO

State

Zip

TRANSFeree:

Name Avinash Nagi Reddy Parisa

Address 1492 Hogback Bridge Road, Earlham, IA 50072

Number and Street or RR

City, Town or PO

State

Zip

Address of Property Transferred:

1492 Hogback Bridge Road, Earlham, IA 50072

Number and Street or RR

City, Town or PO

State

Zip

Legal Description of Property: (Attach if necessary)

See attached

1. Wells (check one)

- No Condition - There are no known wells situated on this property.
 Condition Present - There is a well or wells situated on this property. The type(s), location(s) and legal status are stated below or set forth on an attached separate sheet, as necessary.

2. Solid Waste Disposal (check one)

- No Condition - There is no known solid waste disposal site on this property.
 Condition Present - There is a solid waste disposal site on this property and information related thereto is provided in Attachment #1, attached to this document.

3. Hazardous Wastes (check one)

- No Condition - There is no known hazardous waste on this property.
- Condition Present - There is hazardous waste on this property and information related thereto is provided in Attachment #1, attached to this document.

4. Underground Storage Tanks (check one)

- No Condition - There are no known underground storage tanks on this property. (Note exclusions such as small farm and residential motor fuel tanks, most heating oil tanks, cisterns and septic tanks, in instructions.)
- Condition Present - There is an underground storage tank on this property. The type(s), size(s) and any known substance(s) contained are listed below or on an attached separate sheet, as necessary.

5. Private Burial Site (check one)

- No Condition - There are no known private burial sites on this property.
- Condition Present - There is a private burial site on this property. The location(s) of the site(s) and known identifying information of the decedent(s) is stated below or on an attached separate sheet, as necessary.

6. Private Sewage Disposal System (check one)

- No Condition - All buildings on this property are served by a public or semi-public sewage disposal system.
- No Condition - This transaction does not involve the transfer of any building which has or is required by law to have a sewage disposal system.
- Condition Present - There is a building served by private sewage disposal system on this property or a building without any lawful sewage disposal system. A certified inspector's report is attached which documents the condition of the private sewage disposal system and whether any modifications are required to conform to standards adopted by the Department of Natural Resources. A certified inspection report must be accompanied by this form when recording.
- Condition Present - There is a building served by private sewage disposal system on this property. Weather or other temporary physical conditions prevent the certified inspection of the private sewage disposal system from being conducted. The buyer has executed a binding acknowledgment with the county board of health to conduct a certified inspection of the private sewage disposal system at the earliest practicable time and to be responsible for any required modifications to the private sewage disposal system as identified by the certified inspection. A copy of the binding acknowledgment is attached to this form.
- Condition Present - There is a building served by private sewage disposal system on this property. The system is failing to ensure effective wastewater treatment or is otherwise improperly functioning, and the buyer has executed a binding acknowledgment with the county board of health to install a new private sewage disposal system on this property within an agreed upon time period. A copy of the binding acknowledgment is provided with this form.
- Condition Present - There is a building served by private sewage disposal system on this property. The building to which the sewage disposal system is connected will be demolished without being occupied. The buyer has executed a binding acknowledgment with the county board of health to demolish the building within an agreed upon time period. A copy of the binding acknowledgment is provided with this form. [Exemption #7]
- Condition Present - There is a building served by private sewage disposal system on this property. This property is exempt from the private sewage disposal inspection requirements pursuant to the following Exemption [Note: for exemption #7 use prior check box]: _____
- Condition Present - There is a building served by private sewage disposal system on this property. The private sewage disposal system has been installed within the past two years pursuant to permit number:

Review the following two directions carefully:

- A. If you selected a box stating "No Condition" for every numbered section above, **STOP HERE**. Do not submit this form. Instead, pursuant to Iowa Code section 558.69(8A), you must include the following language on the first page of the recorded deed, instrument, or other writing:


"There is no known private burial site, well, solid waste disposal site, underground storage tank, hazardous waste, or private sewage disposal system on the property as described in Iowa Code section 558.69, and therefore the transaction is exempt from the requirement to submit a groundwater hazard statement."

Please consult your realtor or legal counsel for further advice on this exemption. By law, the owner of the property is responsible for the accuracy of this statement, and the Department provides this information for statutory reference only.

- B. If you checked any box stating "Condition Present" for any of the numbered sections above, continue below. You must complete this form, including providing all required information, and you must submit this form to the county recorder's office with declaration of value.

Information required by statements checked above should be provided here or on separate sheets attached hereto:

I HEREBY DECLARE THAT I HAVE REVIEWED THE INSTRUCTIONS FOR THIS FORM AND THAT THE INFORMATION STATED ABOVE IS TRUE AND CORRECT.

Signature:  Telephone No.: 402 6090619
(Transferor or Agent)

Parcel "F" located in the Northwest Quarter ($\frac{1}{4}$) of the Northwest Quarter ($\frac{1}{4}$) of Section Thirty-five (35), Township Seventy-seven (77) North, Range Twenty-eight (28) West of the 5th P.M., Madison County, Iowa, containing 5.39 acres, as shown in Plat of Survey filed in Book 2006, Page 922 on March 9, 2006, in the Office of the Recorder of Madison County, Iowa; **AND** Parcel "H" located in the Northwest Quarter ($\frac{1}{4}$) of the Northwest Quarter ($\frac{1}{4}$) of said Section Thirty-five (35), containing 5.38 acres, as shown in Plat of Survey filed in Book 2006, Page 1020 on March 16, 2006, in the Office of the Recorder of Madison County, Iowa; **AND** Parcel "G" located in the Southwest Quarter ($\frac{1}{4}$) of the Southwest Quarter ($\frac{1}{4}$) of Section Twenty-six (26), Township Seventy-seven (77) North, Range Twenty-eight (28) West of the 5th P.M., Madison County, Iowa, containing 7.47 acres, as shown in Plat of Survey filed in Book 2006, Page 921 on March 9, 2006, in the Office of the Recorder of Madison County, Iowa.



TIME OF TRANSFER INSPECTION TOT# 6864 JONATHAN CORNISH CERT # 2007

Site Information

Parcel Description: **Madison County sec. 26 Madison twnshp**
Address: **1492 Hog Back Bridge Rd, Earlham, IA 50072** County: **Madison**

Owner Information

Property is owned by a business: **No**
Business Name:
Owner Name: **John Williams**
Email Address: **john.williamsm400@hotmail.com**
Address: **1492 Hog Back Bridge Rd, Earlham, IA 50072**
Phone No: **402-609-0619**

Site related information

No Of Bedrooms: **3** Inspection Date: **08/28/2023**
Facility Type: **Residential** Currently Occupied: **Yes**
Last Occupied: System Installation Date: **03/19/2014**
Permit issued by County: **Yes** Permit Number: **001-14**
All plumbing fixtures enter septic system: **Yes** County contacted for records: **Yes**
Property Information Comments:

Primary Treatment

Tank 1

Tank Name: Tank 1	Type: Septic Tank	Tank Size (Gal): 1500
Tank Material: Concrete	Tank Corrosion Type: None	Liquid Level Type: Normal
No. of Compartments: 3	Pump Tank Chamber: Yes	Licensed Pumper Name: DPS
Date Pumped: 8/28/2023	Meets Setback to Well: N/A	Well Type:
Distance To Well (Ft):	Is Accessible: Yes	Lid Intact: Yes
Risers Intact: Yes	Effluent Filter Present: Yes	Watertight: Yes
Tank/Vault Pumped: Yes	Inlet Baffle Present: Yes	Outlet Baffle Present: Yes
Tank Comments:		Functioning as Designed: Yes

General Primary Treatment Comments:

Distribution Type

Pump System 1

Label: **Pump System 1** Accessible: **Yes** Control Box Functioning: **Yes**
Alarm(s) Present and Functioning: **Yes** Functioning As Designed: **Yes**

General Distribution System Comments :

Secondary Treatment

Sand Filter1

Filter Type: Subsurface	Distribution Type: Pump System	Material Type: Rock and PVC Pipe
Absorption Area: 450	System Hydraulic Loaded: Yes	Gallons Loaded: 450
Discharge At Time of Inspection: No	CBOD Results:	TSS Results:
Disinfection Present: No	Disinfection Type:	Tertiary Treatment Present: No
Tertiary Treatment Type:	Meets Setback to Well: N/A	Well Type:
Distance To Well (Ft.):	Sand Filter Probed: Yes	Vent(s) Located: Yes
Saturation or Ponding Present: No	Grass Cover Over System: Yes	Outlet Found: Yes
Sample Taken: No	GP4 Permitted: No	GP4 Required: No
System Located on Owner Property: Yes	Easement Present: N/A	Functioning as Designed: Yes
Comments:		

General Secondary Treatment Comments:

Narrative Report

TOT Inspection Report Overall Narrative Comments: **Upon inspection the system was in good operating condition. All physical components were in very good condition and were functioning as designed. A hydraulic load test was conducted 2 different times in an effort to collect a laboratory sample of effluent but no effluent was present either time. The sand filter surface was dry with no surface discharge found.**



TIME OF TRANSFER INSPECTION TOT# 6864 JONATHAN CORNISH CERT # 2007

Owner Name: **John Williams**

Address: **1492 Hog Back Bridge Rd , Earlham , IA 50072**

County: **Madison**

Inspection Date: **08/28/2023**

Submitted Date: **8/30/2023**

