



Document 2011 GW3305

Book 2011 Page 3305 Type 43 001 Pages 5
Date 12/08/2011 Time 11:06 AM
Rec Amt \$.00

INDX ✓
ANNO
SCAN
CHEK

LISA SMITH, COUNTY RECORDER
MADISON COUNTY IOWA

**REAL ESTATE TRANSFER - GROUNDWATER HAZARD STATEMENT
TO BE COMPLETED BY TRANSFEROR**

TRANSFEROR:

Name Kaye Loraine Hurst

Address 3126 Timber Ridge Ln Truro IA 50257
Number and Street or RR City, Town or P.O. State Zip

TRANSFeree:

Name Timothy M. Porter

Address 2736 305th St Peru IA 50222
Number and Street or RR City, Town or P.O. State Zip

Address of Property Transferred:

3126 Timber Ridge Ln Truro IA 50257
Number and Street or RR City, Town or P.O. State Zip

Legal Description of Property: (Attach if necessary)

A 5041A SE NE - *See Attached*

1. Wells (check one)

- There are no known wells situated on this property.
- There is a well or wells situated on this property. The type(s), location(s) and legal status are stated below or set forth on an attached separate sheet, as necessary.

2. Solid Waste Disposal (check one)

- There is no known solid waste disposal site on this property.
- There is a solid waste disposal site on this property and information related thereto is provided in Attachment #1, attached to this document.

3. Hazardous Wastes (check one)

- There is no known hazardous waste on this property.
- There is hazardous waste on this property and information related thereto is provided in Attachment #1, attached to this document.

4. Underground Storage Tanks (check one)

- There are no known underground storage tanks on this property. (Note exclusions such as small farm and residential motor fuel tanks, most heating oil tanks, cisterns and septic tanks, in instructions.)
- There is an underground storage tank on this property. The type(s), size(s) and any known substance(s) contained are listed below or on an attached separate sheet, as necessary.

5. Private Burial Site (check one)

- There are no known private burial sites on this property.
- There is a private burial site on this property. The location(s) of the site(s) and known identifying information of the decedent(s) is stated below or on an attached separate sheet, as necessary.

6. Private Sewage Disposal System (check one)

- All buildings on this property are served by a public or semi-public sewage disposal system.
- This transaction does not involve the transfer of any building.
- There is a building served by private sewage disposal system on this property or a building without any lawful sewage disposal system. A certified inspector's report is attached which documents the condition of the private sewage disposal system and whether any modifications are required to conform to standards adopted by the Department of Natural Resources. A certified inspection report must be accompanied by this form when recording.
- There is a building served by private sewage disposal system on this property. Weather or other temporary physical conditions prevent the certified inspection of the private sewage disposal system from being conducted. The buyer has executed a binding acknowledgment with the county board of health to conduct a certified inspection of the private sewage disposal system at the earliest practicable time and to be responsible for any required modifications to the private sewage disposal system as identified by the certified inspection. A copy of the binding acknowledgment is attached to this form.
- There is a building served by private sewage disposal system on this property. The buyer has executed a binding acknowledgment with the county board of health to install a new private sewage disposal system on this property within an agreed upon time period. A copy of the binding acknowledgment is provided with this form.
- There is a building served by private sewage disposal system on this property. The building to which the sewage disposal system is connected will be demolished without being occupied. The buyer has executed a binding acknowledgment with the county board of health to demolish the building within an agreed upon time period. A copy of the binding acknowledgment is provided with this form. [Exemption #9]
- This property is exempt from the private sewage disposal inspection requirements pursuant to the following exemption [Note: for exemption #9 use prior check box]: _____.
- The private sewage disposal system has been installed within the past two years pursuant to permit number 077-11.

Information required by statements checked above should be provided here or on separate sheets attached hereto:

I HEREBY DECLARE THAT I HAVE REVIEWED THE INSTRUCTIONS FOR THIS FORM

AND THAT THE INFORMATION STATED ABOVE IS TRUE AND CORRECT.

Signature: *[Handwritten Signature]*
(Transferor or Agent)

Telephone No.: 515, 210 2945

Legal Description

Parcel "A", located in the Southeast Quarter ($\frac{1}{4}$) of the Northeast Quarter ($\frac{1}{4}$) of Section Twenty (20), Township Seventy-four (74) North, Range Twenty-six (26) West of the 5th P.M., Madison County, Iowa, containing 5.412 acres, as shown in Plat of Survey filed in Book 3, Page 643 on November 7, 2000, in the Office of the Recorder of Madison County, Iowa,

Permit No 077-11 Name: Hurst 911 Sign Locate
 Date of Inspection: 12/5/11 Inspected by: Elton Root
 Contractor: Mark Mease
 Dwelling under construction or moved in Yes No

Setbacks

Meets required setbacks.

- Rural Water Yes No
- Private wells/heat pump wells/suction water lines/takes Yes No
- Outside required 50-foot setback for tank Yes No
- Outside required 100-foot setback for laterals Yes No
- Streams/ponds (25-25 ft)-ditches (10-10 ft) Yes No
- Indications of water lines under pressure Yes No

Comments:

Building Sewer

- Clean outs – one right outside of house Yes No
- location of cleanout inside house and set requirement Yes No
- Pipe is SCH 40 and has a 4-inch diameter. Yes No
- Grade – has adequate fall. Yes No

Comments:

Tank

- Septic Tank Size & Manufacturer 1500 Pella Pre-cast Concrete Plastic
- Pump Tank Size & Manufacturer Concrete Plastic
- Septic compartments, meet the specs for capacity. Yes No
- Baffle Yes No
- Inlet/Outlet tees are ok. Yes No
- Effluent filter in the outlet. Yes No Manuf. Label
- Tank depth. 12
- Risers Yes No
- Lids above grade screwed on Yes No Will be

Comments:

Distribution Box

- Brand Tuf-Tite Other
- Bedded in cement. Yes No Will be
- Has required inlet baffle. Yes No Will be
- Outlet levels –are level. Yes No Unknown

Comments:

Laterals

- Distribution lines: 4 -inch PVC pipe – SCH40
- Lateral used. 36" Chamber Reduction? Yes No
- Lateral depth. 32 inches Perc depth 36 inches
- Laterals were level. Yes No
- Adequate amount of undisturbed soil between laterals. Yes No
- Distance 8 feet between laterals.

Comments:

Permit # 077-11
Inspection 12/5/11
3126 Timber Ridge Ln,

