



Document 2013 GW2586

Book 2013 Page 2586 Type 43 001 Pages 4
Date 9/03/2013 Time 12:24 PM
Rec Amt \$.00

INDX
ANNO
SCAN

LISA SMITH, COUNTY RECORDER
MADISON COUNTY IOWA

CHEK

**REAL ESTATE TRANSFER - GROUNDWATER HAZARD STATEMENT
TO BE COMPLETED BY TRANSFEROR**

TRANSFEROR:

Name DAVID W. HOWELL

Address 1638 195th Street, Winterset, IA 50273
Number and Street or RR City, Town or P.O. State Zip

TRANSFeree:

Name JEFFREY M. GUYER and JESSICA A. GUYER

Address 2108 Earlham Road, Winterset, IA 50273
Number and Street or RR City, Town or P.O. State Zip

Address of Property Transferred:
2108 Earlham Road, Winterset, IA 50273
Number and Street or RR City, Town or P.O. State Zip

Legal Description of Property: (Attach if necessary)
A parcel of land in the NWfr1/4NW1/4 of Section 31-76-28 Madison County, Iowa, containing 3.83 acres as shown in Plat of Survey filed in Book 2, Page 37 on June 17, 1986 Office of Madison County Recorder

1. Wells (check one)

- There are no known wells situated on this property.
- There is a well or wells situated on this property. The type(s), location(s) and legal status are stated below or set forth on an attached separate sheet, as necessary.

2. Solid Waste Disposal (check one)

- There is no known solid waste disposal site on this property.
- There is a solid waste disposal site on this property and information related thereto is provided in Attachment #1, attached to this document.

3. Hazardous Wastes (check one)

- There is no known hazardous waste on this property.
- There is hazardous waste on this property and information related thereto is provided in Attachment #1, attached to this document.

4. Underground Storage Tanks (check one)

- There are no known underground storage tanks on this property. (Note exclusions such as small farm and residential motor fuel tanks, most heating oil tanks, cisterns and septic tanks, in instructions.)
- There is an underground storage tank on this property. The type(s), size(s) and any known substance(s) contained are listed below or on an attached separate sheet, as necessary.

5. Private Burial Site (check one)

- There are no known private burial sites on this property.
- There is a private burial site on this property. The location(s) of the site(s) and known identifying information of the decedent(s) is stated below or on an attached separate sheet, as necessary.

6. Private Sewage Disposal System (check one)

- All buildings on this property are served by a public or semi-public sewage disposal system.
- This transaction does not involve the transfer of any building which has or is required by law to have a sewage disposal system.
- There is a building served by private sewage disposal system on this property or a building without any lawful sewage disposal system. A certified inspector's report is attached which documents the condition of the private sewage disposal system and whether any modifications are required to conform to standards adopted by the Department of Natural Resources. A certified inspection report must be accompanied by this form when recording.
- There is a building served by private sewage disposal system on this property. Weather or other temporary physical conditions prevent the certified inspection of the private sewage disposal system from being conducted. The buyer has executed a binding acknowledgment with the county board of health to conduct a certified inspection of the private sewage disposal system at the earliest practicable time and to be responsible for any required modifications to the private sewage disposal system as identified by the certified inspection. A copy of the binding acknowledgment is attached to this form.
- There is a building served by private sewage disposal system on this property. The buyer has executed a binding acknowledgment with the county board of health to install a new private sewage disposal system on this property within an agreed upon time period. A copy of the binding acknowledgment is provided with this form.
- There is a building served by private sewage disposal system on this property. The building to which the sewage disposal system is connected will be demolished without being occupied. The buyer has executed a binding acknowledgment with the county board of health to demolish the building within an agreed upon time period. A copy of the binding acknowledgment is provided with this form. [Exemption #9]
- This property is exempt from the private sewage disposal inspection requirements pursuant to the following exemption [Note: for exemption #9 use prior check box]: _____
- The private sewage disposal system has been installed within the past two years pursuant to permit number 006-13 installed 3/28/2013.

Information required by statements checked above should be provided here or on separate sheets attached hereto:

1. One well North of South property line in middle of property

I HEREBY DECLARE THAT I HAVE REVIEWED THE INSTRUCTIONS FOR THIS FORM AND THAT THE INFORMATION STATED ABOVE IS TRUE AND CORRECT.

Signature: David W Howell
(Transferor or Agent)

Telephone No.: (515) 250-0261

Madison County
Office of Zoning and
Environmental Health

*Authorization to Construct a
Private On-site Wastewater
Treatment System (POWTS)*

112 N. John Wayne Drive
P.O. Box 152
Winterset, IA 50273-0152
Telephone: (515) 462-2636

Permit Number: 006-13

Date Issued: March 11, 2013

Issued to: Paula Burdock
Address: 2108 Earlham Road
Winterset, Iowa 50273

Legal Description: 3.83A NW PT W 40A N 80A NW EX .12A RD Section 31 T76 R28 Douglas Twp


POWTS Components Specifications: 1250 gal tank – 36” chambers 3 at 92’

General Conditions:

1. System must be constructed in conformance with attached system layout, profiles, and cross-sections.
2. Structures must be constructed in conformance with 567 IAC Chapter 69 and the Madison County Environmental Health Regulations.
3. Permit shall be null and void if system is not constructed within one year of permit issuance. The Environmental Health Officer must approve any request for extension of permit.
4. The Environmental Health Officer must approve any design modifications to the permitted system prior to construction.
5. Once constructed, all system components must be uncovered for inspection and the system must be approved before it can be put into operation. Notice for inspection must be received with 24 hours in advance (8 a.m. through 4:30 p.m., Monday - Friday). If weather necessitates the need to cover the system components, then the system owner or contractor must notify and follow the procedures given by the Environmental Health Officer.

Special Conditions:

Trench maximum depth: 36”



*Environmental Health Officer
Madison County
Office of Zoning and Environmental Health*

Permit No 006-13 Name: Burdock 911 Sign Locate

Date of Inspection: 3/28/13 Inspected by: Elton Root

Contractor: Chad Bengt

Dwelling under construction or moved in Yes No

Setbacks

Meets required setbacks.

- Rural Water Yes No
- Private wells/heat pump wells/suction water lines/lakes Yes No
- Outside required 50-foot setback for tank Yes No
- Outside required 100-foot setback for laterals Yes No
- Streams/ponds (25-25 ft)-ditches (10-10 ft) Yes No
- Indications of water lines under pressure Yes No

Comments:

Building Sewer

- Clean outs – one right outside of house Yes No
- location of cleanout inside house and set requirement Yes No
- Pipe is SCH 40 and has a 4-inch diameter. Yes No
- Grade – has adequate fall. Yes No

Comments:

Tank

- Septic/Pump Tank Size & Manufacturer Lister 1250 Concrete Plastic
- Pump Tank Size & Manufacturer Concrete Plastic
- Septic compartments meet the specs for capacity. Yes No
- Baffle Yes No
- Inlet/Outlet tees are ok. Yes No
- Effluent filter in the outlet. Yes No Manuf. Zabel
- Tank depth 18 inches
- Risers Yes No
- Lids above grade screwed on Yes No Will be

Comments:

Distribution Box

- Brand Tuf-Tite Other
- Bedded in cement. Yes No Will be
- Has required inlet baffle. Yes No Will be
- Outlet levels –are level. Yes No Unknown

Comments:

Laterals

- Distribution lines: 4 -inch PVC pipe – SDR35
- Lateral used. 36" Chamber Reduction? Yes No
- Lateral depth. 30 inches Perc depth 36 inches
- Laterals were level. Yes No
- Adequate amount of undisturbed soil between laterals. Yes No
- Distance 6 feet between laterals.

Comments: