



Document 2016 GW2323

Book 2016 Page 2323 Type 43 001 Pages 7

Date 8/10/2016 Time 11:58:06AM

Rec Amt \$.00

INDX
ANNO
SCAN

LISA SMITH, COUNTY RECORDER
MADISON COUNTY IOWA

CHEK

**REAL ESTATE TRANSFER - GROUNDWATER HAZARD STATEMENT
TO BE COMPLETED BY TRANSFEROR**

TRANSFEROR:

Name Monica Machir

Address 1526 Quarry Trail, Winterset, Iowa 50273

Number and Street or RR

City, Town or P.O.

State

Zip

TRANSFeree:

Name Dallas R. Schechinger

Address 1900 West Jester Park Drive, Polk City, Iowa 50226

Number and Street or RR

City, Town or P.O.

State

Zip

Address of Property Transferred:

1526 Quarry Trail, Winterset, IA 50273

Number and Street or RR

City, Town or P.O.

State

Zip

Legal Description of Property: (Attach if necessary) See 1 in Addendum

1. Wells (check one)

There are no known wells situated on this property.

There is a well or wells situated on this property. The type(s), location(s) and legal status are stated below or set forth on an attached separate sheet, as necessary.

2. Solid Waste Disposal (check one)

There is no known solid waste disposal site on this property.

There is a solid waste disposal site on this property and information related thereto is provided in Attachment #1, attached to this document.

3. Hazardous Wastes (check one)

There is no known hazardous waste on this property.

There is hazardous waste on this property and information related thereto is provided in Attachment #1, attached to this document.

4. Underground Storage Tanks (check one)

There are no known underground storage tanks on this property. (Note exclusions such as small farm and residential motor fuel tanks, most heating oil tanks, cisterns and septic tanks, in instructions.)

There is an underground storage tank on this property. The type(s), size(s) and any known substance(s) contained are listed below or on an attached separate sheet, as necessary.

5. Private Burial Site (check one)

- There are no known private burial sites on this property.
- There is a private burial site on this property. The location(s) of the site(s) and known identifying information of the decedent(s) is stated below or on an attached separate sheet, as necessary.

6. Private Sewage Disposal System (check one)

- All buildings on this property are served by a public or semi-public sewage disposal system.
- This transaction does not involve the transfer of any building which has or is required by law to have a sewage disposal system.
- There is a building served by private sewage disposal system on this property or a building without any lawful sewage disposal system. A certified inspector's report is attached which documents the condition of the private sewage disposal system and whether any modifications are required to conform to standards adopted by the Department of Natural Resources. A certified inspection report must be accompanied by this form when recording.
- There is a building served by private sewage disposal system on this property. Weather or other temporary physical conditions prevent the certified inspection of the private sewage disposal system from being conducted. The buyer has executed a binding acknowledgment with the county board of health to conduct a certified inspection of the private sewage disposal system at the earliest practicable time and to be responsible for any required modifications to the private sewage disposal system as identified by the certified inspection. A copy of the binding acknowledgment is attached to this form.
- There is a building served by private sewage disposal system on this property. The buyer has executed a binding acknowledgment with the county board of health to install a new private sewage disposal system on this property within an agreed upon time period. A copy of the binding acknowledgment is provided with this form.
- There is a building served by private sewage disposal system on this property. The building to which the sewage disposal system is connected will be demolished without being occupied. The buyer has executed a binding acknowledgment with the county board of health to demolish the building within an agreed upon time period. A copy of the binding acknowledgment is provided with this form. [Exemption #9]
- This property is exempt from the private sewage disposal inspection requirements pursuant to the following exemption [Note: for exemption #9 use prior check box]: _____.
- The private sewage disposal system has been installed within the past two years pursuant to permit number _____.

Information required by statements checked above should be provided here or on separate sheets attached hereto:

I HEREBY DECLARE THAT I HAVE REVIEWED THE INSTRUCTIONS FOR THIS FORM AND THAT THE INFORMATION STATED ABOVE IS TRUE AND CORRECT.

Signature: Monica Machin Telephone No.: (515) 669-5777
(Transferor or Agent)

Addendum

1. East Half of the Northeast Quarter of the Northwest Quarter of Section 14, Township 76 North, Range 27 West of the 5th P.M., Madison County, Iowa, more particularly described as follows: Beginning at the North quarter corner of the Section 14, Township 76 North, Range 27 West of the 5th P.M., Madison County, Iowa; thence South $0^{\circ}19'37''$ West along the East line of the Northeast Quarter of the Northwest Quarter of said Section 14, 1321.50 feet to the Southeast corner of the Northeast Quarter of the Northwest Quarter of said Section 14; thence South $89^{\circ}37'31''$ West along an existing fenceline which is the South line of the Northeast Quarter of the Northwest Quarter of said Section 14, 658.43 feet; thence North $0^{\circ}25'28''$ East, 1322.05 feet to a point on the North line of the Northeast Quarter of the Northwest Quarter of said Section 14; thence North $89^{\circ}40'15''$ East along the North line of the Northeast Quarter of the Northwest Quarter of said Section 14; 656.18 feet to the Point of Beginning. Said Parcel contains 19.943 acres, including 0.498 acres of County Road right-of-way.



Time of Transfer Inspection Report

Property Information

Current Owner: Monica Machir
 Buyer: Dallas & Mary Jo Schechinger Realtor: By Owner
 Mailing Address: 1526 Quarry Trail Waukegan IL 50273
 Site Address/County: Same as Above / Madison Co
 Legal Description AS ABSTRACT
 No. of bedrooms: 3 Last occupied: Present Records available: Yes
 Permit/ installation date: 2000 Separation distances (ok/no?): ok

Septic System Information

Septic tank(s): Size: 1,000 gal Material: poly Condition: See Notes
 Tank pumped? Y N Date: 6-7-16 Licensed pumper: Countyside Septic
 Septic/Trash/Processing tank: Size: _____ Material: _____ Condition: _____
 Tank pumped? Y N Date: _____ Licensed pumper: _____
 Aerobic treatment unit (ATU) mfr _____ Size _____
 Tank pumped? Y N Date: _____ Licensed pumper: _____
 Maintenance contract? Y N Expiration date: _____ Service provider: _____
 Condition: _____
 Pump tanks/vaults: Type: _____ Size: _____ Condition: _____
 Distribution system: Distribution box yes Outlets used 3 Condition: ok
 Header pipe(s): _____ No. of lines: _____ Pressure dosed? _____

Secondary Treatment:

Length-of-absorption-fields: 3 100' Determined by: County Records
 Condition of fields: OK - DRY Determined by: probing & hydraulic test
 Type of trench material: Chamber
 Size of sand filter: _____ Determined by: _____
 Vent pipes above grade? Y N Discharge pipe located? Y N
 Effluent sample taken _____ Results: _____
 Media Filters: Type: _____
 Maintenance contract? Y N Expiration date: _____ Service provider: _____
 Condition: _____

NPDES General Permit No. 4: Required? Y N Permitted? Y N NOI provided: _____



Time of Transfer Inspection Report

Other components:

Alarms: Y N Working: Y N Disinfection: Y N Working: Y N

Control Box: _____ Timers: _____ Inspection Ports: _____

Other components: NONE

Overall condition of the private sewage disposal system:

Report system status: See ATTACHED COPY

Explain (attach additional pages as needed): _____

Comments: _____

Site status at conclusion of Time of Transfer inspection:

- Verify that controls are set on the appropriate mode.
- Power is on to all components.
- Revisit all components to verify lids are secure.
- Gather all tools for removal from the site.
- Verify that no sewage is on the ground surface.

Using this worksheet, write a narrative report of the inspection results and attach a site sketch.

This report indicates the condition of the private sewage disposal system at the time of the inspection. It does not guarantee that it will continue to function satisfactorily.

Signature of Certified Inspector: Brian Rinard Date: 6-7-16

Name (print): Brian Rinard Certificate #: 8805

Address: PO Box 204 NORWALK, IA 50211

Phone #: 515-202-4895

Provide a copy of this report, the narrative report and sketch to the seller/agent, buyer/agent or the person ordering the inspection, the county sanitarian/environmental health office and to:

Iowa DNR
Private Sewage Disposal Program
502 E 9th St
Des Moines IA 50319

DNR Time of Transfer Report System Status

Address: 1526 QUARRY TRAIL Date: 6-7-16
Winterset, IA 50273

Comments: Technician DIAN
All WASTEWATER FROM HOUSE APPEARS TO DRAIN
INTO SEPTIC SYSTEM.

1000 gallon poly (2) COMPARTMENT SEPTIC TANK WITH
SMALL RISE OVER INLET SIDE OF SEPTIC TANK. OUTLET
LID WAS CRACKED AND ALSO SLIGHTLY BUCKLED ON
OUTLET SIDE OF THE TANK, THIS HAD NO EFFECT ON
HOW THE SEPTIC SYSTEM FUNCTION.

PLASTIC DISTRIBUTION WITH Baffle AND SPREAD LEVELERS
USED WAS IN GOOD WORKING CONDITION.

All (3) 100' chamber Laterals probed dry AFTER
RUNNING WATER FOR 15-20 MINUTES. THE ENDS OF
EACH LATERAL ARE LOCATED IN hay fields.

THIS IS NOT A GUARANTEE
THIS CERTIFIES THE CONDITION OF
THE SEPTIC SYSTEM AT THE
TIME OF THE INSPECTION.

DIAGRAM OF SYSTEM

See
County
Records

